



PLAINVIEW, TX

explore the opportunities

2022 Annual Drinking Water Quality Report (Consumer Confidence Report)

PWS ID Number: **TX0950004**

PLAINVIEW MUNICIPAL WATER SYSTEM

Phone (806) 296-1100

Annual Water Quality Report for the period of January 1 to December 31, 2022

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

We Welcome Your Comments: There are many opportunities to learn more about the City of Plainview Water Production department and water quality. For questions or concerns about water quality, contact Kendal Minyard at (806) 296-1154. To request a speaker for your group, call (806) 296-1154. For inquiries about public participation and policy decisions, contact the City Manager at (806) 296-1100. The Water Department is part of the city government. The City Council meets on the second and fourth Tuesday of each month. Call (806) 296-1100 for meetings time and locations. You may make written comments to the City of Plainview at 202 W. 5th, Plainview, Texas 79072.

For more information regarding this report contact: Name Kendal Minyard Phone (806) 296-1154

Este informe contiene información muy importante sobre el agua que usted bebe. Si tienes preguntas sobre la calidad del agua, puede llamar a Rick Luna, Ciudad de Plainview, (806) 296-1154. También, puede enviar sus preguntas a Rick Luna, 202 W. 5th, Water Treatment Plant, Plainview, Texas 79072.

Special Notice – Required Language for all Community Public Water Systems: You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791). If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The source of drinking water used by the PLAINVIEW MUNICIPAL WATER SYSTEM is Purchased Surface and Ground Water.

Information on Sources of Water: PLAINVIEW MUNICIPAL WATER SYSTEM purchases water from CANADIAN RIVER MWA. CANADIAN RIVER MWA provides purchase surface water from Lake Meredith located in Sanford, Texas, and groundwater from the Ogallala Aquifer. The City of Plainview also has a total of 15 wells. All of our wells draw water from the Ogallala Aquifer and are active.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Information about Secondary Contaminants

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondaries are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

Information about Source Water Assessments

TCEQ completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confident Report. For more information on source water assessments and protection efforts at our system contact Kendal Minyard at (806) 296-1154.

Definitions and Abbreviations

Definitions and Abbreviations	The following tables contain scientific terms and measures, some of which may require explanation.
Action Level:	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL	million fibers per liter (a measure of asbestos)
mrem:	millirems per year (a measure of radiation absorbed by the body)
na:	not applicable.
NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picocuries per liter (a measure of radioactivity)
ppb:	micrograms per liter or parts per billion
ppm:	milligrams per liter or parts per million
ppq	parts per quadrillion, or picograms per liter (pg/L)
ppt	parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

Water Quality Test Results

Maximum Residual Disinfectant Level

Disinfectant Residue	Year	Average Level	Range of Level Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source of Chemical
Free Chlorine	2022	1.52	1.42-1.76	4	4	mg/l	N	Water additive used to control microbes.

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	0 positive monthly sample	0		0	N	Naturally present in the environment.

Lead and Copper

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
-----------------	--------------	------	-------------------	-----------------	-----------------	-------	-----------	--------------------------------

Copper	2022	1.3	1.3	0.14	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2022	0	15	1.9	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Regulated Contaminants

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)*	2022	13	4.7-15.3	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

* The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year

Total Trihalomethanes (TTHM)*	2022	53	19.6-58.4	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
--------------------------------------	------	----	-----------	-----------------------	----	-----	---	--

* The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	2022	2	2.1-3.6	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Chromium	2022	5.7	2.5-5.7	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.

Barium	2022	0.12	0.1-0.12	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2022	0.09	0.789-2.09	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2022	2	1.17-1.79	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	2022	8.9	8.9-8.9	0	50	pCi/L *	N	Decay of natural and man-made deposits.

*EPA considers 50 pCi/L to be the level of concern for beta particles.

Gross alpha excluding radon and uranium	2022	2	2-2	0	15	pCi/L	N	Erosion of natural deposits.
Uranium	2022	6.5	6.5-6.5	0	30	ug/l	N	Erosion of natural deposits.

Turbidity

	Level Detected	Limit (Treatment Technique)	Violation	Likely Source of Contamination
Highest single measurement	0.8 NTU	1 NTU	N	Soil runoff.
Lowest monthly % meeting limit	100%	0.3 NTU	N	Soil runoff.

Violations Table

N/A

Plainview is Water Wise - Water Meter Project

The City of Plainview completed a Long-Range Water Supply Plan in 2021. The Plan identified water conservation as a key component of extending our water supplies, thus saving valuable resources.

In Fall of 2022, City of Plainview staff began analyzing the potential of installing Automatic Metering Infrastructure (AMI) in our service area, replacing aging water meters and addressing aging infrastructure associated with our facilities.

The purpose of the project is to replace the aging water meter system to achieve operational efficiencies, reduce energy and operational costs, and water meter loss all while providing many benefits to our citizens such as transparency and accurate billing, water conservation, and enhanced service to our citizens.

New meters and meter boxes are scheduled to be installed beginning Fall 2023. Once the new water meter infrastructure is active, customers will have access to water-use data via a customer portal. For the most up-to-date information regarding this project, please visit the City of Plainview's website – www.plainviewtx.org.

Plainview is Water Wise – we encourage everyone to conserve water through various conservation methods. For additional information, contact the City of Plainview at 806-296-1100 or visit www.plainviewtx.org.